

Town: CONWAY

EPA Id: NH 0512190

System Name: BROOK VIEW VILLAGE

Pop Served: 40

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400003	FLUORIDES	MCL VIOLATION	4.00000	3.40000000	02/07/2005	

EPA Id: NH 0512010

System Name: C W C /BIRCH HILL EAST

Pop Served: 315

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400010	FLUORIDES	MCL VIOLATION	4.00000	2.50000000	02/08/2005	

EPA Id: NH 0512020

System Name: C W C /BIRCH HILL WEST

Pop Served: 113

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400004	FLUORIDES	MCL VIOLATION	4.00000	2.70000000	02/10/2005	

EPA Id: NH 0512280

System Name: C W C/BIRCH HILL EAST II

Pop Served: 55

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400007	FLUORIDES	MCL VIOLATION	4.00000	3.10000000	02/07/2005	

EPA Id: NH 0512030

System Name: CATHEDRAL LEDGE

Pop Served: 150

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400012	FLUORIDES	MCL VIOLATION	4.00000	3.10000000	02/10/2005	

EPA Id: NH 0512200

System Name: CEDAR CREEK

Pop Served: 105

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400022	ARSENIC	MCL VIOLATION	0.01000	0.05800000	04/09/2004	
400023	ARSENIC	MCL VIOLATION	0.01000	0.05600000	06/25/2004	
400024	ARSENIC	MCL VIOLATION	0.01000	0.05400000	08/08/2004	
400026	FLUORIDES	MCL VIOLATION	4.00000	3.60000000	02/07/2005	
500025	ARSENIC	MCL VIOLATION	0.01000	0.05400000	12/02/2004	

Town: CONWAY

EPA Id: NH 0516030

System Name: CONWAY MUNICIPAL CENTER

Pop Served: 36

PWS Type: NON-TRANSIENT NON-COMMUNITY

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400016	FLUORIDES	MCL VIOLATION	4.00000	3.70000000	02/07/2005	

EPA Id: NH 0512260

System Name: DAVIS HILL

Pop Served: 75

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400004	URANIUM /(MASS units in ug/L)	MCL VIOLATION	30.00000	133.00000000	06/04/2004	
400005	URANIUM /(MASS units in ug/L)	MCL VIOLATION	30.00000	133.00000000	11/05/2004	
400007	FLUORIDES	MCL VIOLATION	4.00000	2.20000000	02/10/2005	
500006	URANIUM /(MASS units in ug/L)	MCL VIOLATION	30.00000	132.00000000	11/19/2004	

EPA Id: NH 0512150

System Name: DEERBROOK CONDOS

Pop Served: 68

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400003	FLUORIDES	MCL VIOLATION	4.00000	2.20000000	02/10/2005	

EPA Id: NH 0512050

System Name: ECHO LAKE WOODS

Pop Served: 112

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400004	FLUORIDES	MCL VIOLATION	4.00000	3.40000000	02/07/2005	

EPA Id: NH 0512060

System Name: FOREST EDGE

Pop Served: 118

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400019	FLUORIDES	MCL VIOLATION	4.00000	2.10000000	02/10/2005	

EPA Id: NH 0512070

System Name: FOREST PARK VILLAGE

Pop Served: 45

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400021	FLUORIDES	MCL VIOLATION	4.00000	2.80000000	02/10/2005	

Town: CONWAY

EPA Id: NH 0512230

System Name: MELODY PINES CONDOS

Pop Served: 125

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400004	FLUORIDES	MCL VIOLATION	4.00000	3.60000000	02/07/2005	
400005	URANIUM /(MASS units in ug/L)	MCL VIOLATION	30.00000	55.00000000	05/20/2005	

EPA Id: NH 0515020

System Name: NEW PINE TREE SCHOOL

Pop Served: 380

PWS Type: NON-TRANSIENT NON-COMMUNITY

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400014	FLUORIDES	MCL VIOLATION	4.00000	2.30000000	02/10/2005	

EPA Id: NH 0512110

System Name: NORTH PINES ASSOC

Pop Served: 67

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400002	FLUORIDES	MCL VIOLATION	4.00000	2.10000000	02/10/2005	

EPA Id: NH 0512180

System Name: SACO PINES

Pop Served: 50

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400018	FLUORIDES	MCL VIOLATION	4.00000	2.40000000	02/10/2005	

EPA Id: NH 0512140

System Name: SOUTH PINES

Pop Served: 70

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400013	FLUORIDES	MCL VIOLATION	4.00000	2.80000000	02/10/2005	

**Description of Data Reported****PWS: Public Water System**

**Town:** Town, city or unincorporated place - political boundary in which the system is located.

**EPA Id:** Also known as PWS Id. State and Federal number assigned to track PWS.

**System Name:** Legal name of PWS.

**Pop Served:** The population served by PWS.

**PWS Type:** Type of PWS based on Federal Definition.

**Community:** Residential system capable of serving at least 25 residents.

**Non-Community Non-Transient:** Non-residential system capable of serving at least 25 of the same people 6 months a year.

**Non-Community Transient:** A system capable of serving water to at least 25 people 60 days a year.

**Viol Id:** The Federal Fiscal Year plus the violation identifier assigned by Environmental Services.

**Contaminant:** The contaminant and/or rule of which the PWS is in violation.

**Violation Description:** The type of violation.

**Awareness:** Date the state became aware of the MCL or TT violation.

**MCL (Maximum Contaminant Level):** The highest amount of a contaminant that the EPA allows in drinking water. MCLs are defined in milligrams per liter (Mg/l) (parts per million) unless otherwise specified.

**Result: Chemical Monitoring (Phase I, II, IIB and V) Rules:** The analytical result(s) that caused the MCL violation.

**Bacteria (Total Coliform) Rule:** PRESENT indicates an MCL violation. ie., coliform is present.

**Lead and Copper Rule and Surface Water Treatment Rule:** TT (Treatment Technique) Violation or failure to meet operational and/or system requirements under the rule.

**Comp Achved:** The date the PWS returned to compliance for the violation.

\* The violations listed are based on both Env-WS300 "NH Drinking Water Rules" and 40 CFR Part 141-143 "National Primary Drinking Water Regulations, Secondary Drinking Water Regulations"

--- END OF REPORT ---